

## Ventura County Environmental Health Division 800 S. Victoria Ave., Ventura CA 93009-1730 TELEPHONE: 805/654-2813 or FAX: 805/654-2480 https://vcrma.org/divisions/environmental-health

**Daily Log of Pool Chemistry** 

							9				
Name of Pool Facility				Location/Adress				Name of Pool Service Company		Phone No. Pool Service	
Date	Pool Type	Free	pH <sup>2</sup>	Controller	Controller	Spa Temp.	Flow rate	e Influent	Remark	ke·	Operato
Date	Pool, Spa, Wader, ect	Chlorine <sup>1</sup>	μι-	ORP	pH	ора тетір.	(gpm)		e.g., filters cleaned/backwashed, equ (type/amo	ipment repairs, chemicals added	initials
Monthly T		Cyanuric Acid (Cl <sub>2</sub> stabilizer)		Total Alkalinity		Calcium Hardness		Remarks:			
Date	Id	Ideal Range 20-40 ppm Max 100 ppm		Ideal Range 80-110 ppm		Ideal Range 200- 400 ppm					
									C	Operator's Initials	

<sup>&</sup>lt;sup>1</sup>Free chlorine residual: Swimming Pool minimum 1.0 ppm un-stabilized and 2.0 ppm stabilized, and a maximum of 10.0 ppm.